

LOG OF WELL

KIND OF ROCK OR OTHER MATERIAL (Give color and tell whether hard or soft)	DEPTH, IN FEET		THICKNESS, IN FEET	REMARKS (Especially information as to water found)
	From—	To—		
Soil	0	1-2		
Sand and gravel (clean)	2	20	18	
<p>Lakeland 5-4455 2/21/54 note: Mr. Schwaninger from New York City at about 400-450 gpm says pump was tested at 500 gpm at rating is for new pump is probably closer due to fact that at rating is for new pump no other are further down. no answer Mr. Schwaninger Cold Sp. 5-3165 Lakeland 4455; 8-4401; 8-5738 2/18/54 (Sch) called Putnam Valley Fire Dept. 500 gpm 4455 8-2100</p>				
<p>Pumped by fire dept. at 30(?) gpm with 18' of head in one hour. Could not lower below screen of pump at end of hour. note: Called Albany Fire Dept. and was told by fire chief that was a old fashioned fire truck such as that used by fire dept. volunteer fire dept. (most in Putnam County) would be capable of 500 gpm. This figure has therefore been used for yield figure. 4/5/54</p>				